



TYPE EXAMINATION CERTIFICATE FIRE RESISTANCE OF LIFTS LANDING DOORS

Issued by Liftinstituut B.V.

Certificate no. : NL08-400-1002-110-01/1 Revision no.: 1

Description of the product : Fire resistant side opening telescopic lift landing door

Trademark, type : Prolift, Telescopic Lift Landing door PRL C150-015 T2

Name and address of the manufacturer : Prolift Asansör San.ve Tic. Aş
Büyükbalklı Mah. Büyükbalklı Cad. No:157/A-157/B
Nilüfer / Bursa / Turkey

Name and address of the certificate holder : Prolift Asansör San.ve Tic. Aş
Büyükbalklı Mah. Büyükbalklı Cad. No:157/A-157/B
Nilüfer / Bursa / Turkey

Certificate issued on the following requirements : Lifts Directive 2014/33/EU

Certificate based on the following standard : EN 81-58:2003

Test laboratory : FIRES, s.r.o.

Date and number of the laboratory report : February 25, 2009, FIRES-FR-011-09-AUNE

Date of type examination : February 6, 2009
Rev.1; September 15, 2017

Classification : The performance criteria of the EN 81-58 covered is: E-120

Additional document with this certificate : Report belonging to the type examination certificate
no.: NL08-400-1002-110-01 rev.1

Additional remarks : None

Conclusion : The Prolift landing door meets the requirements of the Lift
Directive, Annex I section 4.2 and the EN 81-58:2003, in
particular for the classification indicated above.

Amsterdam

Date : 15-09-2017
Valid until : 15-09-2022

ing. J.L. van Viet
Managing Director

Certification decision by